



**GFC Sys I TAS
Tube Type Anti-Swirl Device
Turbine Meters**

Min	Rec	Description
L1	10d	Distance from meter run valve or piping disturbance to flow meter inlet
L2	3d	Distance from GFC profile device inlet to flow meter inlet
L3	3.5d	Distance from GFC anti-swirl inlet to profile device inlet
L4	3d	Distance from meter run valve or piping disturbance to GFC anti-swirl inlet

THIS DRAWING IN DESIGN AND DETAIL IS THE PROPERTY OF Sorvant Measurement Corporation ALL RIGHTS RESERVED	
MESSAGE: ANY REPRODUCTION OF THIS DRAWING WITHOUT THE WRITTEN PERMISSION OF Sorvant Measurement Corporation IS STRICTLY PROHIBITED. ALL RIGHTS RESERVED.	
TITLE: GFC Installation	DWG. NO.: Sys I TAS Turbine
DATE: 15 JUN 00	SCALE: N/A
APPVD: PNJ	SHEET: 1 of 1