



**Min Rec Description**

- L1 10d 10d Distance from meter run valve or piping disturbance to flow meter inlet
- L2 3d 5d Distance from GFC profile device inlet to flow meter inlet
- L3 3.5d 5d Distance from GFC anti-swirl inlet to profile device inlet
- L4 2.5d 3.5d Distance from blow-down or thermowell to profile device inlet
- L5 1d 1.5d Distance from GFC anti-swirl inlet to blow-down or thermowell

**GFC Sys I VAS  
Vane Type Anti-Swirl Device  
Ultrasonic Meters**

THIS DRAWING IN DESIGN AND DETAIL IS THE PROPERTY OF Savant Measurement Corporation. IT SHALL NOT BE REPRODUCED AND SHALL BE RETURNED TO US ON DEMAND. ALL RIGHTS RESERVED.	
DRN: PNJ APPVD:	TITLE: <b>GFC Installation</b> DWG. NO. Sys I VAS USM 4-36 DATE 05MAY00 SCALE N/A SHEET 1 of 1