



**GFC Sys VI
2.469" and smaller Turbine Meters**

Min	Rec	Description
L1	10d	Distance from meter run valve or piping disturbance to flow meter inlet
L2	3d	Distance from GFC profile device inlet to flow meter inlet
L3	3d	Distance from meter run valve or piping disturbance to GFC profile device inlet

THIS DRAWING IN DESIGN AND DETAIL IS THE PROPERTY OF Savant Measurement Corporation IT SHALL NOT BE REPRODUCED AND SHALL BE RETURNED TO US ON DEMAND ALL RIGHTS RESERVED			
Savant Measurement Corporation		DATE 15JUN00	
TITLE: GFC Installation		DWG. NO. Sys VI Turbine	
DRN: PNJ		SCALE N/A	
APPROV.:		SHEET 1 of 1	
REV. A			