



Range	Rec	Description
L1 13D+	13D	Distance from meter run valve or piping disturbance to orifice plate
L2 5-11D	7D	Distance from flow conditioner pin location to orifice plate
L3 5D+	10D	Distance from meter run valve or piping disturbance to flow conditioner pin location
L4 3D+	8D	Distance from blow-down to flow conditioner pin location

pFC
For 2-4" Orifice Only

Rec Lengths meet
AGA3 April 2000 Revision